

**ANNEX II TO CERTIFICATE OF CONFORMITY OF CONSTANCY OF PERFORMANCE**  
**1922-CPR-1276/ 14.04.2020**  
**EN 54-17:2006, EN 54-17:2005/AC:2007**

Essential Characteristics	Performance	Clause
<b>Nominal activation conditions / sensitivity / response delay (response time) and performance under fire conditions</b>		
<b>Performance under fire conditions</b>		
- Reproducibility	Pass	5.2
<b>Operational reliability</b>		
- Requirements	Pass	4
<b>Durability of operational reliability, temperature resistance</b>		
- Dry heat (operational)	Pass	5.4
- Cold (operational)	Pass	5.5
<b>Durability of operational reliability, vibration resistance</b>		
- Shock (operational)	Pass	5.9
- Impact (operational)	Pass	5.10
- Vibration, sinusoidal (operational)	Pass	5.11
- Vibration, sinusoidal (endurance)	Pass	5.12
<b>Durability of operational reliability, humidity resistance</b>		
- Damp heat, cyclic (operational)	Pass	5.6
- Damp heat, steady state (endurance)	Pass	5.7
<b>Durability of operational reliability, corrosion resistance</b>		
- Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	NPD	5.8
<b>Durability of operational reliability, electrical stability</b>		
- Variation of supply parameters	Pass	5.3
- Electromagnetic compatibility (EMC), immunity tests (operational)	Pass	5.13



Embossed stamp of "Dedal - A&C" Ltd.



*Anna Vasileva*

Manager:



dipl. eng. Anna Vasileva